




EXTERIOR SWITCH
(Active Only when
Relay-2 will active)




INTERIOR BUTTON
(Always unlocks &
opens the door)



**ACCESS CONTROL,
TIME CLOCK or FIRE ALARM**

(NON-POWERED & MAINTAINED SIGNAL to
keep door unlocked for desired time)



RELAY-1
TIME 5-30S
ADJUSTABLE

POWER
12/24 V
AC/DC

Activation
Wires

DOOR OPERATOR

ELECTRIC STRIKE
(For Mag Lock Use
COM and NC)

- +
**POWER
FOR
STRIKE**

FARRON

DOOR AUTOMATION


2074 Steeles Ave E. Unit 12
Brampton, ON L6T 4Z9
905-792-2829
farrondooraautomation.com

FARRON DOOR AUTOMATION


ACCESS INTEGRATOR

DWG NO. FA-2612


EXTERIOR SWITCH
(Active Only when
Relay-2 is active)



INTERIOR BUTTON
(Always unlocks &
opens the door)



ACCESS CONTROL
TIME CLOCK or FIRE ALARM
(POWERED & MAINTAINED SIGNAL
6-24V For to Keep door unlocked
for desired time)



RELAY-1
TIME 5-30S
ADJUSTABLE

POWER
12/24 V
AC/DC

DOOR OPERATOR

Activation
Wires

ELECTRIC STRIKE
(For Mag Lock Use
COM and NC)

**POWER
FOR
STRIKE**

FARRON DOOR AUTOMATION

2074 Steeles Ave E. Unit 12
Brampton, ON L6T 4Z9
905-792-2829
farrondooraautomation.com

FARRON DOOR AUTOMATION

ACCESS INTEGRATOR

DWG NO. FA-2612